

Surveyed October 22, 2018

San Onofre Inspection Report

Edison Survey reported Nov. 10, 2020

AHSM	Inlet Vent Contact ( $\mu\text{R/hr}$ )	Inlet Vent 1 foot away ( $\mu\text{R/hr}$ )	DSC SERIAL No.	UNIT FUEL	DATE ON PAD	HEAT LOAD (Kw)	BURNUP (GWd/MTU)	MAXIMUM FUEL ENRICHMENT %	PERSON REM DOSE
1	800	500	DSC003	1	10/3/2003	9.35	36.0	4.0006	1.366
2	700	500	DSC007	1	11/7/2003	9.36	37.3	4.0006	0.667
3	800	500	DSC005	1	11/19/2003	9.31	37.0	4.0006	0.681
4	800	500	DSC006	1	12/12/2003	8.84	37.6	4.0006	0.673
5	700	500	DSC009	1	1/3/2004	8.34	34.9	4.0006	0.695
6	700	500	DSC008	1	5/23/2004	7.50	40.0	4.02	1.021
7	600	400	DSC011	1	6/6/2004	7.46	37.6	4.02	1.043
8	700	500	DSC010	1	6/20/2004	8.08	38.5	4.02	0.776
9	700	500	DSC012	1	7/3/2004	8.44	38.1	4.02	0.734
10	600	400	DSC014	1	7/18/2004	7.74	36.7	4.02	0.689
11	800	500	DSC015	1	7/30/2004	7.46	38.8	4.02	0.633
12	700	500	DSC013	1	8/16/2004	8.45	40.6	4.02	0.545
13	600	400	DSC016	1	8/20/2004	7.87	40.3	4.02	0.560
14	500	300	DSC017	1	8/31/2004	7.23	43.2	4.02	0.348
15	100	70	DSC018	1 GTCC	9/2/2004	N/A	N/A	N/A	0.555
16	420	260	DSC002	1	5/29/2005	7.37	42.8	4.00	0.570
17	440	240	DSC004	1	6/10/2005	8.15	38.3	4.00	0.431
18	440	270	DSC001	1	6/28/2005	8.11	41.8	4.00	0.453
19	1400	900	DSC019	2	3/6/2007	11.96	48.3	4.04	0.849
20	1300	1000	DSC020	2	3/19/2007	12.05	44.8	3.97	0.819
21	1600	1100	DSC021	2	4/5/2007	12.13	44.8	3.97	0.502
22	1000	700	DSC022	2	4/16/2007	10.51	38.5	3.95	0.262
23	1000	700	DSC023	2	4/30/2007	11.89	38.6	3.96	0.308
24	900	600	DSC024	2	5/14/2007	11.07	41.1	3.97	0.192
25	600	400	DSC025	2	5/29/2007	9.66	38.3	3.97	0.126
26	380	220	DSC026	3	3/5/2008	8.29	38.2	3.96	0.149
27	1000	600	DSC027	3	3/18/2008	9.99	38.2	3.96	0.262
28	800	600	DSC028	3	4/1/2008	9.68	37.1	3.96	0.217
29	1000	700	DSC029	3	4/23/2008	11.14	50.1	3.97	0.275
30	1200	800	DSC030	3	5/29/2008	8.49	36.7	3.96	0.143
31	800	500	DSC031	3	6/9/2008	7.78	29.5	3.46	0.074
32	1200	700	DSC032	2	3/19/2009	12.37	46.0	4.49	0.328
33	900	500	DSC033	2	4/8/2009	12.85	42.5	4.49	0.177
34	1100	800	DSC034	2	4/30/2009	13.64	42.9	4.49	0.248
35	900	500	DSC035	2	5/13/2009	13.00	45.8	4.48	0.180
36	1100	700	DSC036	2	5/30/2009	14.71	46.0	4.49	0.220
37	1000	600	DSC037	3	5/13/2010	13.16	48.0	4.60	0.360
38	1200	800	DSC038	3	5/26/2010	14.46	46.0	4.60	0.342
39	1000	600	DSC039	3	6/9/2010	13.16	48.0	4.50	0.278
40	1100	700	DSC040	3	6/21/2010	15.04	47.0	4.60	0.326
41	1100	700	DSC041	3	7/3/2010	15.26	47.0	4.60	0.326

AHSM	Inlet Vent Contact ( $\mu$ R/hr)	Inlet Vent 1 foot away ( $\mu$ R/hr)	DSC SERIAL No.	UNIT FUEL	DATE ON PAD	HEAT LOAD (Kw)	BURNUP (GWd/MTU)	MAXIMUM FUEL ENRICHMENT %	PERSON REM DOSE
42	1100	700	DSC042	3	7/13/2010	15.39	47.0	4.60	0.288
43	320	180	DSC043	2	7/11/2011	7.81	44.7	4.45	0.159
44	320	180	DSC044	2	7/26/2011	8.75	42.8	4.44	0.127
45	310	170	DSC045	2	8/8/2011	8.76	43.7	4.45	0.107
46	310	210	DSC046	2	8/26/2011	8.78	43.7	4.44	0.114
47	310	180	DSC047	2	9/10/2011	8.88	41.8	4.16	0.095
48	900	600	DSC048	3	5/23/2012	8.06	40.6	3.96	0.131
49	700	500	DSC049	3	6/16/2012	12.24	45.4	4.25	0.265
50	360	210	DSC050	3	6/28/2012	12.31	44.6	4.49	0.157
51	360	220	DSC051	3	7/8/2012	13.16	51.4	4.55	0.175

<https://www.nrc.gov/docs/ML1919/ML19190A217.pdf>

<https://www.nrc.gov/docs/ML1901/ML19011A457.pdf>

[https://www.songscommunity.com/\\_gallery/get\\_file/?file\\_id=5fad7bd92cfac21c607ecc54&ir=1&file\\_ext=.pdf](https://www.songscommunity.com/_gallery/get_file/?file_id=5fad7bd92cfac21c607ecc54&ir=1&file_ext=.pdf)